

2016 Food Booth and Vendor Requirements

The use of food booth is regulated by the Fair Board for Health and Safety.

Failure to comply with the following requirements and regulations may result in closure of the location.

Flame Retardant Requirements

The sidewalls, drops and tops of tents and canopies shall be flame resistant material or treated with a flame retardant in an approved manner. An Idaho Fire tag shall be permanently fixed to the structure.

Portable Fire Extinguishers

A portable fire extinguisher must be in each booth. The minimum size for extinguisher is 2A 10B: C (5 lbs.). If a fryer is being used, a K TYPE extinguisher shall also be required. Extinguishers shall have a current Idaho Fire tag. The extinguishers shall be in an accessible and visible location.

Location

Food booth vendor shall have a clearance of at least 10 feet on two sides. Cooking that produces sparks or grease-laden vapors shall not be conducted within 10 feet of a structure.

Gas Stoves

All gas stoves and burners shall be listed by either Underwriters Laboratories (UL) or the American Gas Association (AGA).

Fryers

Fryers shall not be used in food vendor tents. If a fryer is to be used it shall be outside the tent and at least 10 feet from the outside wall of that tent. If a fryer is used in conjunction with a BBQ, it shall be 3 feet away from the BBQ. Fryers also require the addition of a K TYPE fire extinguisher.

Barbeques

Barbeques are not permitted within the food booth, and shall be located at least 10 feet from a structure or combustible materials. Fuel for barbeques shall be kept at least 10 feet away from the barbeque. Barbeques and other open flame devices located outside of structure shall be secured from fallings and contact by the public.

Smoking

Smoking is not allowed at anytime within the food booth, or within 25 feet of any fuel source.

Generators

Generators shall be located a minimum of 20 feet from tents or canopies. They shall also be isolated from contact with the public by approved means. The refueling of hot generators is not allowed.

A copy of these requirements and regulations shall be posted in the structure and signed by the vendor. By signing this form the vendor agrees to comply with these rules. The signed copy will be available on request for review by the Sandpoint Fire Chief.

Food Booth Operator's Signature

Date(s) of Event

Booth Name

Fire Department Inspector

Date of Inspection