

**Addendum No. 2
December 29, 2022**

LEA COUNTY, NEW MEXICO



**ALABAMA STREET RECONSTRUCTION
NIGP COMMODITY CODE # 91371
BID # 03 - (22-23)**

NOTICE TO BIDDERS:

1. This Addendum is issued to all plan holders. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
2. The Bidder shall acknowledge receipt of this Addendum in Section 3 – Bid Form, page 3.2.
3. All terms, conditions, and requirements of the original project manual and construction documents shall remain in place unless explicitly mentioned in this Addendum.
4. All bids shall be sealed, addressed and delivered **no later than 2:00 p.m. (local time) on Tuesday, January 03, 2023** to the:
Finance Director
Finance Department, 4th Floor
Lea County Courthouse
100 N. Main, Suite 11
Lovington, New Mexico 88260-4030
5. Bids will be officially opened and publicly read aloud **after 2:00 p.m. (local time) Tuesday, January 03, 2023** in the:
Commission Chambers, 1st Floor
Lea County Courthouse
100 N. Main
Lovington, New Mexico 88260

Addendum No. 2
December 29, 2022

6. Question: For Bid Item 57062A 42" SX29"R CMP ARCH PIPE (SKEW 60) it shows 42" at 60 Degree Skew. However, on sheet 2-8 30 Degree Skew and 36" Dia. is highlighted. Also, on Sheet 3-3 of the P&P, these pipes are referring to details on Sheets 13-17, 13-18 & 13-19. These sheets also shows a 42" Dia. but no reference to the skew.

Answer: Pipe size and skew are noted correctly in the bid item description (42"x29" with 60 degree skew). Highlighted items on sheet 2-8 are for reference only. Contractor shall provide pricing for end sections assuming a 60 degree skew.



David Roybal, P.E.
Project Engineer



Acknowledgement of this Addendum is required in Section 3 – Bid Form, Page 3.2.