

## **25.1.10. Liquid petroleum gas containers**

### **25.1.10.1.6**

Containers for liquefied petroleum gases shall be installed not less than 5 ft (1.5 m) from any tent or temporary membrane structure and shall be in accordance with the provisions of Chapter 69.

### **25.1.10.1.7**

Tanks shall be secured in the upright position and protected from vehicular traffic.

## **25.1.12 Generators.**

### **25.1.12.1**

Generators and other internal combustion power sources shall be separated from temporary membrane structures and tents by a minimum of 5 ft (1.5 m) and shall be protected from contact by fencing, enclosure, or other approved means.

## **25.1.12.3 Fire Extinguishers.**

### **25.2 Tents.**

#### **25.2.1 General.**

##### **25.2.1.1**

Tents shall be permitted only on a temporary basis. [**101**:11.11.1.2]

##### **25.2.1.2**

Tents shall be erected to cover not more than 75 percent of the premises, unless otherwise approved by the AHJ. [**101**:11.11.1.3]

#### **25.2.2 Flame Propagation Performance.**

##### **25.2.2.1**

All tent fabric shall meet the flame propagation performance criteria contained in Test Method 2 of **NFPA 701**. [**101**:11.11.2.1]

##### **25.2.2.2**

One of the following shall serve as evidence that the tent fabric materials have the required flame propagation performance:

1. (1)The AHJ shall require a certificate or other evidence of acceptance by an organization acceptable to the AHJ.
2. (2)The AHJ shall require a report of tests made by other inspection authorities or organizations acceptable to the AHJ. [**101**:11.11.2.2]

##### **25.2.2.3**

Where required by the AHJ, confirmatory field tests shall be conducted using test specimens from the original material, which shall have been affixed at the time of manufacture to the exterior of the tent. [**101**:11.11.2.3]

#### **25.2.3 Location and Spacing.**

##### **25.2.3.1**

There shall be a minimum of 10 ft (3050 mm) between stake lines. [**101**:11.11.3.1]

##### **25.2.3.2**

Adjacent tents shall be spaced to provide an area to be used as a means of emergency egress. Where 10 ft (3050 mm) between stake lines does not meet the requirements for means of egress, the distance necessary for means of egress shall govern. [**101**:11.11.3.2]

### 25.2.3.3

Tents not occupied by the public and not used for the storage of combustible material shall be permitted to be erected less than 10 ft (3050 mm) from other structures where the AHJ deems such close spacing to be safe from hazard to the public. [101:11.11.3.3]

### 25.2.3.4

Tents, each not exceeding 1200 ft<sup>2</sup> (112 m<sup>2</sup>) in finished ground level area and located in fairgrounds or similar open spaces, shall not be required to be separated from each other, provided that safety precautions meet the approval of the AHJ. [101:11.11.3.4]

### 25.2.3.5

The placement of tents relative to other structures shall be at the discretion of the AHJ, with consideration given to occupancy, use opening, exposure, and other similar factors. [101:11.11.3.5]

A minimum of one portable fire extinguisher with a rating of not less than 2-A:10-B:C shall be provided.

## PARK SAFE

1. Give space (15 feet for fire hydrants and 10 feet for everything else).
2. Don't park in fire lanes or fire department access roads.
3. Stabilize your food truck when its parked (wheel chocks or jacks).

