

FIRE MARSHALL REQUIREMENTS

CONCESSIONAIRES

- Each concessionaire is required to have a **2A10BC** fire extinguisher in a visible location.
- Each concessionaire that is cooking with vegetable or animal oils and fats must also have a K Type fire extinguisher located in a visible location.
- Each fire extinguisher must be tagged by an approved agency within the past year and not expected to expire before the end of the fair.
- If the concessionaire has an Ansul type system over their cooking system, they must also have been inspected and tagged by an approved agency, (as specified on Item 3).

COMMERCIAL VENDORS

- Any commercial vendor utilizing an open flame within their display is required to have a 2A10BC fire extinguisher in a visible location.
- Any commercial vendor utilizing an open flame within their display is to take the necessary precautions not to have the flame on an open aisle close to the public. Demonstrations must be out of the public's reach.

The Fire Marshalls will be onsite Tuesday, September 27, and Wednesday, September 28, 2022 to make their rounds. They have requested that all concessionaires and those commercial vendors utilizing an open flame have their fire extinguisher at the front of their booth for inspection. This will enable you to place it once inspected and approved prior to the fair opening.

FIRE MARSHALL REQUIREMENTS

VEHICLES, RV'S, BOATS or MOTORCRAFT EQUIPMENT

- Batteries are disconnected
- Fuel in fuel tanks does not exceed ¼ tank or 5 gallons (whichever is less)
- Vehicles, boats or other motor craft equipment are not fueled or defueled within the building
- Fuel tanks and fill openings are closed and sealed to prevent tampering